GA

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	–	–	–	SPACE ONLY	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	–	–	–	SPACE ONLY	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	15	16	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	**EXISTING CIRCUIT**	–	**20/1**	**EXIST**	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	23	24	EXIST	20/1	–	EXISTING CIRCUIT	–
–	**EXISTING CIRCUIT**	–	**20/1**	**EXIST**	25	26	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	27	28	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	29	30	**NEW**	**20/1**	**12**	**DELAY EGRESS HARDWARE (NOTE 1)**	**360**
–	EXISTING CIRCUIT	–	20/1	EXIST	31	32	**NEW**	**20/1**	**12**	**GE216B REFRIG. (NOTE 1) (GFI)**	**800**
–	EXISTING CIRCUIT	–	20/1	EXIST	33	34	**NEW**	**20/1**	**12**	**GE186 MICROWAVE (NOTE 1)**	**1680**
–	EXISTING CIRCUIT	–	20/1	EXIST	35	36	**NEW**	**20/1**	**12**	**REFRIG. LEAK DETECTION SYS. (NOTE 1)**	**1000**
–				EXIST	37	38	–	–	–	SPACE ONLY	–
–	EXISTING CIRCUIT	–	60/3	EXIST	39	40	–	–	–	SPACE ONLY	–
–				EXIST	41	42	–	–	–	SPACE ONLY	–

LOCATION : ELECTRICAL ROOM
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 225 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

NOTES:
1. PROVIDE AND INSTALL NEW BREAKER AS INDICATED IN EXISTING SPACE. TYPE AND AIC RATING TO MATCH EXISTING.
2. (GFI) GFCI TYPE BREAKER

EXISTING PANEL

EXISTING DEMAND LOAD = 14,580 VA
NET LOAD ADDITION = 3,840 VA
TOTAL = 18,420 VA
(51 AMPS)

H

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	21	22	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	23	24	–	–	–	SPACE ONLY (P49)	–
–	SPARE	–	20/1	EXIST	25	26	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	27	28	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	29	30	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	31	32	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	33	34	EXIST	20/1	–	SPARE	–
–	SPARE	–	20/1	EXIST	35	36	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	37	38	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	39	40	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	41	42	EXIST	20/1	–	EXISTING CIRCUIT	–

LOCATION : GROCERY STAGING
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 225 AMP MLO
FED FROM PANEL "MDP" (200A)

P13
P47

EXISTING PANEL

(EXISTING LOADS UNCHANGED)

HA

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	23	24	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	25	26	EXIST	20/1		EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	27	28	EXIST	20/1		EXISTING CIRCUIT	–
– (P47)	EXISTING CIRCUIT	–	20/1	EXIST	29	30	EXIST	20/1	–	SPARE	–
–	SPARE	–	20/1	EXIST	31	32	EXIST	20/1	–	SPARE	–
–	EXISTING CIRCUIT	–	20/1	EXIST	33	34	EXIST	20/1	–	SPARE	–
–	SPARE	–	20/1	EXIST	35	36	EXIST	20/1		EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	37	38	**EXIST**	**20/1**	**10**	**FLORAL TRACK LIGHTING**	**1349**
–	EXISTING CIRCUIT	–	20/1	EXIST	39	40	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	41	42	EXIST	20/1	–	EXISTING CIRCUIT	–

LOCATION : ELECTRICAL ROOM
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 225 AMP MLO
FED FROM PANEL "MDP" (200A)

P13

EXISTING PANEL

(NEW LOADS OFFSET BY REMOVAL OF EXISTING)

F

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	**(NOTE 1) EXISTING CIRCUIT** (P44)	**12**	**20/1**	**NEW**	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	**EXIST**	**20/1**	**12**	**PLPROWS BOOSTER PUMP**	**200**
–	SPACE ONLY	–	–	–	9	10	EXIST	30/1	–	EXISTING CIRCUIT	–
–	SPACE ONLY	–	–	–	11	12	**NEW**	**20/2**	**10**	**PMSC8M PRODUCE CASE (NEW BRKR–NOTE 1)**	**988**
–	SPACE ONLY	–	–	–	13	14	**NEW**				**988**
–	SPACE ONLY	–	–	–	15	16	**NEW**	**20/2**	**10**	**PMSC8M PRODUCE CASE (NEW BRKR–NOTE 1)**	**988**
–	SPACE ONLY	–	–	–	17	18	**NEW**				**988**
–	SPACE ONLY	–	–	–	19	20	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	21	22	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	23	24	–	–	–	SPACE ONLY	–

LOCATION : GROCERY STAGING
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

NOTES:
1. REPLACE EXISTING BREAKER WITH NEW AS INDICATED. TYPE AND AIC RATING TO MATCH EXISTING.
2. PROVIDE AND INSTALL NEW BREAKER AS INDICATED IN EXISTING SPACE. TYPE AND AIC RATING TO MATCH EXISTING.

EXISTING PANEL

EXISTING DEMAND LOAD = 15,300 VA
NET LOAD ADDITION = 4,152 VA
TOTAL = 19,452 VA
(54 AMPS)

FA

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	23	24	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	25	26	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	27	28	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	29	30	**NEW**	**20/1**	**12**	**SS12HC–DSFM – A/S (NOTE 1)**	**134**
–	EXISTING CIRCUIT	–	20/1	EXIST	31	32	–	–	–	SPACE ONLY	–
–	EXISTING CIRCUIT	–	30/1	EXIST	33	34	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	35	36	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	37	38	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	39	40	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	41	42	–	–	–	SPACE ONLY	–

LOCATION : ELECTRICAL ROOM
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

NOTES:
1. PROVIDE AND INSTALL NEW BREAKER AS INDICATED IN EXISTING SPACE. TYPE AND AIC RATING TO MATCH EXISTING.

EXISTING PANEL

EXISTING DEMAND LOAD = 18,720 VA
NET LOAD ADDITION = 134 VA
TOTAL = 18,854 VA
(52 AMPS)

G

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	**NEW**	**20/2**	**10**	**P1DSC6J PRODUCE CASE (NEW BRKR–NOTE 1)**	**1564**
–	SPARE	–	20/1	EXIST	3	4	**NEW**				**1564**
–	SPARE	–	20/1	EXIST	5	6	EXIST	15/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	7	8	EXIST	15/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	9	10	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	15	16	EXIST	15/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	23	24	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	25	26	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	27	28	**NEW**	**20/2**	**10**	**PMSC8M PRODUCE CASE (NEW BRKR–NOTE 1)**	**988**
720	**CONF. ROOM RECEPTS.**	**10**	**20/1**	**EXIST**	29	30	**NEW**				**988**
1500	**270V COFFEE MKR**	**10**	**20/1**	**EXIST**	31	32	EXIST	20/1	–	EXISTING CIRCUIT	–
960	**E7MDF PRINTER**	**10**	**20/1**	**EXIST**	33	34	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	35	36	–	–	–	SPACE ONLY	–
–	SPARE	–	20/1	EXIST	37	38	**NEW**	**25/1**	**10**	**MMSC4HC MEAT CASE (NEW BRKR–NOTE 1)**	**2345**
700	**HDR2 HAND DRYER (NEW BRKR–NOTE 1)**	**10**	**15/2**	**NEW**	39	40	**NEW**	**15/2**	**10**	**HDR2 HAND DRYER (NEW BRKR–NOTE 1)**	**700**
700				**NEW**	41	42	**NEW**				**700**

LOCATION : GROCERY STAGING
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 225 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

NOTES:
1. PROVIDE AND INSTALL NEW BREAKER AS INDICATED IN EXISTING SPACE. TYPE AND AIC RATING TO MATCH EXISTING.
2. REPLACE EXISTING SPARE BREAKER WITH NEW AS INDICATED. TYPE AND AIC RATING TO MATCH EXISTING.

EXISTING PANEL

EXISTING DEMAND LOAD = 5,040 VA
NET LOAD ADDITION = 13,429 VA
TOTAL = 18,469 VA
(51 AMPS)

D

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	**EXIST**	**20/1**	**10**	**BAKERY CASE – FANS**	**144**
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/2	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–				EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
95	**SS12HC–DSFM CASE – FANS**	**12**	**20/1**	**EXIST**	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPACE ONLY	–	–	–	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPACE ONLY	–	–	–	23	24	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPACE ONLY	–	–	–	25	26	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	27	28	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	29	30	**NEW**	**25/1**	**10**	**S7 SEAFOOD STEAMER (NOTE 1)**	**2160**

LOCATION : GROCERY STAGING
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

NOTES:
1. PROVIDE AND INSTALL NEW BREAKER AS INDICATED IN EXISTING SPACE. TYPE AND AIC RATING TO MATCH EXISTING.

EXISTING PANEL

EXISTING DEMAND LOAD = 11,520 VA
NET LOAD ADDITION = 2,469 VA
TOTAL = 13,989 VA
(39 AMPS)

DA

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/2	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–				EXIST	19	20	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	21	22	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	23	24	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1		25	26	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	27	28	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	29	30	EXIST	20/1	–	EXISTING CIRCUIT	–

LOCATION : ELECTRICAL ROOM
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

EXISTING PANEL

(NO CHANGE TO EXISTING LOADS)

E

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	13	14	–	–	–	SPACE ONLY	–
–	SPARE	–	20/1	EXIST	15	16	–	–	–	SPACE ONLY	–
–	SPARE	–	20/1	EXIST	17	18	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	19	20	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	21	22	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	23	24	–	–	–	SPACE ONLY	–

LOCATION : GROCERY STAGING
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

EXISTING PANEL

(NO CHANGE TO EXISTING LOADS)

EA

VA	SERVICE	WIRE	MOPD	TYPE	CIR.	CIR.	TYPE	MOPD	WIRE	SERVICE	VA
–	EXISTING CIRCUIT	–	20/1	EXIST	1	2	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	3	4	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	5	6	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	7	8	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	9	10	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	11	12	EXIST	20/1	–	EXISTING CIRCUIT	–
–	EXISTING CIRCUIT	–	20/1	EXIST	13	14	EXIST	20/1	–	EXISTING CIRCUIT	–
234	**BAKERY CASE – LTS**	**10**	**20/1**	**EXIST**	15	16	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	17	18	EXIST	20/1	–	EXISTING CIRCUIT	–
–	SPARE	–	20/1	EXIST	19	20	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	21	22	–	–	–	SPACE ONLY	–
–	SPACE ONLY	–	–	–	23	24	–	–	–	SPACE ONLY	–

LOCATION : ELECTRICAL ROOM
PANEL MOUNTING : SURFACE
SERVICE : 120/208V, 3PH, 4W
MAINS : 100 AMP MLO
FED FROM PANEL "MDP" (100A)

P13

EXISTING PANEL

EXISTING DEMAND LOAD = 7,560 VA
NET LOAD ADDITION = 234 VA
TOTAL = 7,794 VA
(22 AMPS)

SPECIAL REPAIR NOTES

PXX SEE SPECIAL REPAIR NOTE LIST ON SHEET E6.2. REFER TO CRESCENT CONSTRUCTION SERVICES, LLC ELECTRICAL SURVEY REPORT FOR ADDITIONAL INFORMATION.

NOTE:
EXISTING PANEL INFORMATION OBTAINED FROM AS–BUILT DRAWINGS. FIELD VERIFY EXISTING CONDITIONS AND AVAILABILITY OF ANY NEW BREAKERS PRIOR TO SUBMITTING BID. VERIFY LOADS ON EXISTING PANELS AND AFFECTED CIRCUITS. DO NOT OVERLOAD PANELS.

NOTE:
WIRE SIZE BASED ON ESTIMATED LEGNTHS. E.C. TO ADJUST AS NECESSARY TO LIMIT VOLTAGE DROP TO 3% OR LESS.

NOTE:
ELECTRICAL CONTRACTOR SHALL PROVIDE, INSTALL AND UTILIZE TEMPORARY ELECTRICAL PANEL COVERS SIMILAR TO GRACE PRODUCTS, MITCHELL, SP PRODUCTS, OR EQUALS WHENEVER PERMANENT COVERS HAVE BEEN REMOVED FOR NEW WORK OR SERVICING. PANEL COVERS, WHETHER PERMANENT OR TEMPORARY SHALL BE IN PLACE AT ALL TIMES ON ENERGIZED PANELS.

NOTE:
E.C. TO COPY AND/OR PHOTOGRAPH ALL EXISTING PANEL DIRECTORIES PRIOR TO COMMENCING WORK AND RETAIN FOR USE IN CREATING NEW, UPDATED DIRECTORIES FOR ALL PANELS UPON COMPLETION OF THE PROJECT. NEW PANEL DIRECTORIES TO BE TYPE WRITTEN AND SHALL INDICATE AS CLEARLY AS POSSIBLE LOADS SERVED. NEW DIRECTORIES WILL BE REQUIRED FOR ALL PANELS, NEW AND EXISTING. DO NOT USE PANEL SCHEDULES FROM THESE DRAWINGS AS SUBSTITUTES FOR DIRECTORIES.

GA	F	D
H	FA	DA
HA	G	E
–	–	EA

CAPSTONE
project services, plc
2211 WIDMAN WAY, STE 220
FORT MYERS, FL 33901

COMMONWEALTH OF VIRGINIA
STEVE W. HAAS
No. 023587
PROFESSIONAL ENGINEER
6–1–2020
SEAL

STEVE W. HAAS, P.E.
ELECTRICAL ENGINEER
10130 PERIMETER PKWY, STE 200
CHARLOTTE, NC
(704) 330–6500
haasandkenne@mpinet.com

CONSULTANT

A REMODEL FOR:
KROGER R–215
7480 LEE HWY
FAIRLAWN, VA

PROJECT KROGER MID-ATLANTIC

6-1-2020
DATE CONSTRUCTION SET

PANEL SCHEDULES
SHEET TITLE

REVISIONS

MARK	DATE	DESCRIPTION

PROJECT NO: 20201
CAD DWG FILE: R–215 E6.2.2
DRAWN BY: WSM
CHK'D BY: SWH

E6.2.2
SHEET NO.