

Western Environmental Services, Inc.

P.O. Box 19021
Roanoke, VA 24019
Phone (540) 265-0988
Fax (540) 265-6798

October 27, 2016

Kroger Mid-Atlantic
Facility Engineering
3631 Peters Creek Road
Roanoke, VA 24019

Re: Kroger R-215
7480 Lee Highway
Radford, VA
WES Project #16-45.1

Dear Mr. Tom Poole

Western Environmental Services, Inc. has completed the asbestos inspection & survey for the Kroger R-215 building located at 7480 Highway of Radford, Virginia. The purpose of this inspection was to determine the presence of friable and non-friable Asbestos Containing Materials (ACMs) in this facility. This building is a one-story building ~ 53,000 SF of space.


This inspection is required by the Department of General Services for renovation and/or demolition of existing structures. The site visit & inspection for the Kroger R-215 building was performed on October 21, 2016 and the building is going to be scheduled for interior renovations.

Samples were obtained from areas of the ceiling tile, drywall/joint compound, cove base mastic, carpet mastic, stair tread mastic and floor tile/mastic. A total of thirty-eight (38) samples of suspect material were obtained and forwarded to Schneider Laboratories, Inc. in Richmond, VA for analysis. Of the thirty-eight (38) samples analyzed, NONE were reported to contain more than 1% asbestos mineral content.

FRIABLE ASBESTOS-CONTAINING MATEIALS
WES, Inc.# DESCRIPTION

ASBESTOS TYPE & PERCENTAGE

NONE FOUND



CATEGORY I & II NON-FRIABLE ASBESTOS-CONTAINING MATERIALS

| <u>WES, Inc.#</u> | <u>DESCRIPTION</u> | <u>ASBESTOS TYPE & PERCENTAGE</u> |
|-------------------|--------------------|---------------------------------------|
|-------------------|--------------------|---------------------------------------|


****NONE FOUND****

Western Environmental Services, Inc. has conducted a survey and sample program within the scope and sample limitations of this assignment. Our survey does not guarantee that the listed products are the only ACMs in this facility. It only states that a diligent survey was performed and that these materials were not found to contain greater than 1% asbestos minerals.

Additional suspect materials may exist in areas concealed behind walls, equipment or other finishes which could not be entered during this inspection. Utility related materials may also vary through the building.

We appreciate being of service to you. Should you have any questions or wish to discuss this report, please feel free to contact me at (540) 265-0988.

Very truly yours,



Nick Palmieri, President


Western Environmental Services, Inc.
VA Inspector #1204

Enclosures



10-16 Sample Locations For Asbestos Survey

Kroger R-215
7480 Lee Hwy,
Radford, VA



MID-ATLANTIC

MINOR CAPITAL
R-215
7480 LEE HWY
RADFORD, VA

| | |
|-------------|------|
| NO. 450/205 | DATE |
| PROJECT | DATE |
| DESCRIPTION | DATE |
| BY | DATE |
| CHECKED | DATE |
| APPROVED | DATE |

FINAL PLAN
R-215
F1



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Western Environmental Services, Inc. (1546)
Address: 7410 Sunnybrook Dr
 Roanoke, VA 24019

Order #: 189807

Attn:
Project: Kroger R - 215
Location: 7480 Lee Hwy. Radford, VA
Number: #45.1

Received 10/26/16
Analyzed 10/27/16
Reported 10/27/16

PO Number:

Method: EPA 600/R-93/116 & 600/M4-82-020


PLM Analysis

| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|------------|--|----------|--------------------------|-----------------|---|
| 189807-001 | 10/21/16 | L-1 | Office Area | None Detected | 40% CELLULOSE FIBER 10% FOAMED GLASS 40% MINERAL/GLASS WOOL 10% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile White/Gray, Fibrous | | | | |
| 189807-002 | 10/21/16 | L-2 | Office Area | None Detected | 40% CELLULOSE FIBER 10% FOAMED GLASS 40% MINERAL/GLASS WOOL 10% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile White/Gray, Fibrous | | | | |
| 189807-003 | 10/21/16 | L-3 | Office Area | None Detected | 40% CELLULOSE FIBER 10% FOAMED GLASS 40% MINERAL/GLASS WOOL 10% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile White/Gray, Fibrous | | | | |
| 189807-004 | 10/21/16 | L-4 | Employ. Closet/Bath Hall | None Detected | 45% CELLULOSE FIBER 5% FOAMED GLASS 45% MINERAL/GLASS WOOL 5% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile Tan, Fibrous | | | | |
| 189807-005 | 10/21/16 | L-5 | Employ. Closet/Bath Hall | None Detected | 45% CELLULOSE FIBER 5% FOAMED GLASS 45% MINERAL/GLASS WOOL 5% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile Tan, Fibrous | | | | |
| 189807-006 | 10/21/16 | L-6 | Employ. Closet/Bath Hall | None Detected | 45% CELLULOSE FIBER 5% FOAMED GLASS 45% MINERAL/GLASS WOOL 5% NON FIBROUS MATERIAL |
| | Layer 1: Ceiling Tile Tan, Fibrous | | | | |

Reporting Limit: 1% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite sample with a trace (<1) or greater amount of asbestos is a concern and should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.

| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|------------|---------------------|----------|----------------------------|-----------------|--------------------------|
| 189807-007 | 10/21/16 | L-7 | Main FL | | |
| Layer 1: | Ceiling Tile | | | None Detected | 40% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 10% FOAMED GLASS |
| | | | | | 40% MINERAL/GLASS WOOL |
| | | | | | 10% NON FIBROUS MATERIAL |
| 189807-008 | 10/21/16 | L-8 | Main FL | | |
| Layer 1: | Ceiling Tile | | | None Detected | 45% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 5% FOAMED GLASS |
| | | | | | 45% MINERAL/GLASS WOOL |
| | | | | | 5% NON FIBROUS MATERIAL |
| 189807-009 | 10/21/16 | L-9 | Main FL | | |
| Layer 1: | Ceiling Tile | | | None Detected | 45% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 5% FOAMED GLASS |
| | | | | | 45% MINERAL/GLASS WOOL |
| | | | | | 5% NON FIBROUS MATERIAL |
| 189807-010 | 10/21/16 | L-10 | Meat/Sea/Bake Meat | | |
| Layer 1: | Ceiling Tile | | | None Detected | 45% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 5% FOAMED GLASS |
| | | | | | 45% MINERAL/GLASS WOOL |
| | | | | | 5% NON FIBROUS MATERIAL |
| 189807-011 | 10/21/16 | L-11 | Meat/Sea/Bake | | |
| Layer 1: | Ceiling Tile | | | None Detected | 45% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 5% FOAMED GLASS |
| | | | | | 45% MINERAL/GLASS WOOL |
| | | | | | 5% NON FIBROUS MATERIAL |
| 189807-012 | 10/21/16 | L-12 | Meat/Sea/Bake | | |
| Layer 1: | Ceiling Tile | | | None Detected | 45% CELLULOSE FIBER |
| | White/Gray, Fibrous | | | | 5% FOAMED GLASS |
| | | | | | 45% MINERAL/GLASS WOOL |
| | | | | | 5% NON FIBROUS MATERIAL |
| 189807-013 | 10/21/16 | L-13 | Main FL Meat/Sea/Bake a | | |
| Layer 1: | Drywall | | | None Detected | 15% CELLULOSE FIBER |
| | White, Powdery | | | | 85% NON FIBROUS MATERIAL |
| 189807-014 | 10/21/16 | L-14 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Drywall | | | None Detected | 15% CELLULOSE FIBER |
| | White, Powdery | | | | 85% NON FIBROUS MATERIAL |
| 189807-015 | 10/21/16 | L-15 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Drywall | | | None Detected | 15% CELLULOSE FIBER |
| | White, Powdery | | | | 85% NON FIBROUS MATERIAL |

Reporting Limit: 1% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite sample with a trace (<1) or greater amount of asbestos is a concern and should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.




Method: EPA 600/R-93/116 & 600/M4-82-020

PLM Analysis

| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|------------|---|----------|-----------------------|-----------------|---------------------------|
| 189807-016 | 10/21/16 | L-16 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Joint Compound White, Granular | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-017 | 10/21/16 | L-17 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Joint Compound White, Granular | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-018 | 10/21/16 | L-18 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Joint Compound White, Granular | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-019 | 10/21/16 | L-19 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Floor Tile Green/Blue, Organically Bound | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-020 | 10/21/16 | L-20 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Mastic Yellow, Brittle | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-021 | 10/21/16 | L-21 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Floor Tile Tan/Brown, Organically Bound | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-022 | 10/21/16 | L-22 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Mastic Dark Yellow, Soft | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-023 | 10/21/16 | L-23 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Floor Tile White/Gray, Organically Bound | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-024 | 10/21/16 | L-24 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Mastic Yellow, Brittle | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-025 | 10/21/16 | L-25 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Floor Tile White/Gray, Organically Bound | | | None Detected | 100% NON FIBROUS MATERIAL |
| 189807-026 | 10/21/16 | L-26 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Mastic Yellow, Brittle | | | None Detected | 100% NON FIBROUS MATERIAL |

Reporting Limit: 1% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite sample with a trace (<1) or greater amount of asbestos is a concern and should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.




| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|------------|---------------------------------|----------|-----------------------|-----------------|---------------------------|
| 189807-027 | 10/21/16 | L-27 | Produce Area | | |
| Layer 1: | Floor Tile | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Green/Black, Organically Bound | | | | |
| 189807-028 | 10/21/16 | L-28 | Produce Area | | |
| Layer 1: | Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-029 | 10/21/16 | L-29 | Produce Area | | |
| Layer 1: | Floor Tile | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Orange/Black, Organically Bound | | | | |
| 189807-030 | 10/21/16 | L-30 | Produce Area | | |
| Layer 1: | Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-031 | 10/21/16 | L-31 | Produce Area | | |
| Layer 1: | Floor Tile | | | None Detected | 100% NON FIBROUS MATERIAL |
| | White/Black, Organically Bound | | | | |
| 189807-032 | 10/21/16 | L-32 | Produce Area | | |
| Layer 1: | Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-033 | 10/21/16 | L-33 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Cove Base Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-034 | 10/21/16 | L-34 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Cove Base Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-035 | 10/21/16 | L-35 | Main FL Meat/Sea/Bake | | |
| Layer 1: | Cove Base Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Yellow, Soft | | | | |
| 189807-036 | 10/21/16 | L-36 | C Entrance | | |
| Layer 1: | Carpet Mastic | | | None Detected | 100% NON FIBROUS MATERIAL |
| | Black, Soft | | | | |
| Layer 2: | Carpet | | | None Detected | 5% NON FIBROUS MATERIAL |
| | Gray/White, Fibrous | | | | 95% SYNTHETIC FIBER |

Reporting Limit: 1% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite sample with a trace (<1) or greater amount of asbestos is a concern and should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.

Method: EPA 600/R-93/116 & 600/M4-82-020

PLM Analysis


| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|---|-----------|----------|-----------------|-----------------|---------------------------|
| 189807-037 | 10/21/16 | L-37 | Upstairs Office | None Detected | 100% NON FIBROUS MATERIAL |
| Layer 1: Carpet Mastic Yellow, Brittle | | | | | |
| 189807-038 | 10/21/16 | L-38 | Office Area | None Detected | 100% NON FIBROUS MATERIAL |
| Layer 1: Mastic Beige, Rubbery | | | | | |



Analyst: Hashim, Reel
Total layers analyzed on order: 39
189807-10/27/16 12:33 PM

Reviewed By: Hind Eldanaf
Microscopy Supervisor

Reporting Limit: 1% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite sample with a trace (<1) or greater amount of asbestos is a concern and should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.





SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
 www.slabin.com e-mail: info@slabin.com

189807

S 38



V:189\189807

fghraizi
U.S. Mail

10/26/2016 10:2 5:00 AM

| | | |
|---|--|--|
| Submitting Co. WESTERN ENV. SERVICES | Lab WO# | Phone 540-265-0988 |
| P O BOX 19021 | Acct # 1546 | Fax / Email 540-265-6798 |
| ROANOKE, VA 24019 | **State of Collection VA | **Cert. Required <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Project Name: Kroger R-215 | Special Instructions [include requests for special reporting or data packages] | |
| Project Location: 7480 Lee Hwy. Radford, VA | | |
| Project Number: #45.1 | | |
| PO Number: | | |

| Turn Around Time (TAT) | Matrix / Sample Type (Select ONE) | Tests / Analytes (Select ALL that Apply) | | |
|--|---|---|---|---|
| <input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day* † <input checked="" type="checkbox"/> 1 business day* † <input type="checkbox"/> 2 business days* † <input type="checkbox"/> 3 business days* † <input type="checkbox"/> 5 business days* † * Not available for all tests A job received past 3PM † will begin its TAT the next business day Schedule rush organics, multi-metals & weekend tests in advance. | All samples on form should be of SAME matrix type. Use additional forms as needed. <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input checked="" type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> <input type="checkbox"/> Soil <input type="checkbox"/> | Asbestos in Air: <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) Miscellaneous Tests: <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) <input type="checkbox"/> Other | Asbestos in Bulk: <input checked="" type="checkbox"/> PLM <input type="checkbox"/> PLM (Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP <input type="checkbox"/> CAELAP (Point Count) <input type="checkbox"/> TEM (Chafield) | Metals-Total: <input type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals TCLP: <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) 10 day Microbiology: <input type="checkbox"/> BACT (MPN & PIA) <input type="checkbox"/> Mold Direct Exam |

| Sample # | Date Sampled** | Time Sampled** | Sample Identification (Employee, SSN, Bldg, Material, Type ¹) | Wiped Area (ft ²) | pH / Temp * | Time ² | | Flow Rate ³ | | Total ⁴ Air |
|----------|----------------|----------------|---|-------------------------------|-------------|-------------------|------|------------------------|------|------------------------|
| | | | | | | Start | Stop | Start | Stop | |
| L-1 | 10-21-16 | | 2x4 White Ceiling Tile w/ pinholes | | | | | | | |
| L-2 | | | ↓ | | | | | | | |
| L-3 | | | ↓ | | | | | | | |
| L-4 | | | 2x4 Tan Ceiling Tile w/ streaks | | | | | | | |
| L-5 | | | ↓ | | | | | | | |
| L-6 | | | ↓ | | | | | | | |
| L-7 | | | 2x4 White Ceiling Tile w/ pinholes | | | | | | | |
| L-8 | | | ↓ | | | | | | | |
| L-9 | | | ↓ | | | | | | | |
| L-10 | | | 2x4 White Ceiling Tile w/ smooth finish | | | | | | | |

¹Type: A=Area B=Blank P=Personal E=Excursion ²Beginning/End of Sample Period ³Pump Calibration in Liters/Minute ⁴Volume in Liters (time in min * flow in L/min)
 All soil and aqueous samples must be sent in adequate quantity for duplicate analysis to be performed per EPA requirements. Failure to perform a sample duplicate analysis, due to a lack of sample quantity, will lead to a disclaimer on the report. All problem jobs without customer response held over 30 days will be voided and disposed of.

| | | |
|--|---|---|
| Sampled by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Relinquished to lab by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Sample Disposal <input type="checkbox"/> Return to Sender (shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee for excessive weight) Shipping Methods <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: |
| <input type="checkbox"/> Sample return requested <input type="checkbox"/> Ambient temp <input type="checkbox"/> Ice <input type="checkbox"/> CI <input type="checkbox"/> R <input type="checkbox"/> S <input type="checkbox"/> X <input type="checkbox"/> Receive a physical copy of report. | | |

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.



SCHNEIDER LABORATORIES GLOBAL, INC.

WO Label

2512 West Cary Street, Richmond, Virginia 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
 www.slabin.com e-mail: info@slabin.com

| | | |
|---|--|---|
| Submitting Co. WESTERN ENV. SERVICES | Lab WO# | Phone 540-265-0988 |
| P O BOX 19021 | Acct # 1546 | Fax / Email 540-265-6798 |
| ROANOKE, VA 24019 | **State of Collection VA | **Cert Required <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Project Name: Kroger R-215 | Special Instructions [Include requests for special reporting or data packages] | |
| Project Location: 7480 Lee Hwy. Radford, VA | | |
| Project Number: #45.1 | | |
| PO Number: | | |

| Turn Around Time (TAT) | Matrix / Sample Type (Select ONE) | Tests / Analytes (Select ALL that Apply) | | |
|--|--|---|---|--|
| <input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day † <input checked="" type="checkbox"/> 1 business day* † <input type="checkbox"/> 2 business days* † <input type="checkbox"/> 3 business days* † <input type="checkbox"/> 5 business days* † <small>* Not available for all tests</small> <small>A job received past 3PM † will begin its TAT the next business day</small> <small>Schedule rush organics, multi-metals & weekend tests in advance.</small> | <small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input checked="" type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> <input type="checkbox"/> Soil <input type="checkbox"/> | Asbestos in Air <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) Miscellaneous Tests <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7802) <input type="checkbox"/> Silica - XRD (NIOSH 7800) Other <input type="checkbox"/> | Asbestos in Bulk <input checked="" type="checkbox"/> PLM <input type="checkbox"/> PLM (Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP <input type="checkbox"/> CAELAP (Point Count) <input type="checkbox"/> TEM (Chatfield) <input type="checkbox"/> | Metals-Total <input type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals TCLP <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) 10 day Microbiology <input type="checkbox"/> BACT (MPN & P/A) <input type="checkbox"/> Mold Direct Exam <input type="checkbox"/> |

| Sample # | Date Sampled** | Time Sampled** | Sample Identification (Employee, SSN, Bldg, Material, Type') | Wiped Area (ft²) | pH / Temp * | Time² | | Flow Rate³ | | Total⁴ Air |
|----------|----------------|----------------|--|------------------|-------------|-------|------|------------|------|------------|
| | | | | | | Start | Stop | Start | Stop | |
| L-11 | 10-21-16 | | 2x4 White Ceiling Tile w/ smooth finish | | | | | | | |
| L-12 | | | ↓ | | | | | | | |
| L-13 | | | Dry Wall Main Floor / Meat / Seafood / Bakery | | | | | | | |
| L-14 | | | ↓ | | | | | | | |
| L-15 | | | ↓ | | | | | | | |
| L-16 | | | Joint Compound Main Floor / Meat / Seafood / Bakery | | | | | | | |
| L-17 | | | ↓ | | | | | | | |
| L-18 | | | ↓ | | | | | | | |
| L-19 | | | 12x12 green floor tile w/ spears | | | | | | | |
| L-20 | | | mastic to above | | | | | | | |

*Type: A=Area B=Blank P=Personal E=Excursion ²Beginning/End of Sample Period ³Pump Calibration in Liters/Minute ⁴Volume in Liters [time in min * flow in L/min]
 All soil and aqueous samples must be sent in adequate quantity for duplicate analysis to be performed per EPA requirements. Failure to perform a sample duplicate analysis, due to a lack of sample quantity, will lead to a disclaimer on the report. All problem jobs without customer response held over 30 days will be voided and disposed of.

| | | |
|--|---|---|
| Sampled by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Relinquished to lab by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Sample Disposal <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee for excessive weight) Shipping Methods <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: |
| <input type="checkbox"/> Sample return requested <input type="checkbox"/> Ambient temp <input type="checkbox"/> Ice <input type="checkbox"/> CI <input type="checkbox"/> R <input type="checkbox"/> S <input type="checkbox"/> X <input type="checkbox"/> Receive a physical copy of report. | | |

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.





SCHNEIDER LABORATORIES GLOBAL, INC.

WO Label

2512 West Cary Street, Richmond, Virginia 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
 www.slabinc.com e-mail: info@slabinc.com

| | | |
|---|--|--|
| Submitting Co. WESTERN ENV. SERVICES | Lab WO# | Phone 540-265-0988 |
| P O BOX 19021 | Acct # 1546 | Fax / Email 540-265-6798 |
| ROANOKE, VA 24019 | **State of Collection VA | **Cert. Required <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Project Name: Kroger R-215 | Special Instructions [Include requests for special reporting or data packages] | |
| Project Location: 7480 Lee Hwy. Radford, VA | | |
| Project Number: # 451 | | |
| PO Number: | | |


| Turn Around Time (TAT) | Matrix / Sample Type (Select ONE) | Tests / Analytes (Select ALL that Apply) | | |
|---|--|---|---|--|
| <input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day* † <input checked="" type="checkbox"/> 1 business day* † <input type="checkbox"/> 2 business days* † <input type="checkbox"/> 3 business days* † <input type="checkbox"/> 5 business days* † <small>* Not available for all tests † A job received past 3PM will begin its TAT the next business day Schedule rush organics, multi-metals & weekend tests in advance.</small> | <small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input checked="" type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> HI-Vol Filter (PM10) <input type="checkbox"/> Water, Drinking <input type="checkbox"/> HI-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> <input type="checkbox"/> Soil <input type="checkbox"/> | Asbestos In Air <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) Miscellaneous Tests <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) <input type="checkbox"/> Other | Asbestos In Bulk <input checked="" type="checkbox"/> PLM <input type="checkbox"/> PLM (Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP <input type="checkbox"/> CAELAP (Point Count) <input type="checkbox"/> TEM (Chatfield) | Metals-Total <input type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals TCLP <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) 10 day Microbiology <input type="checkbox"/> BACT (MPN & P/A) <input type="checkbox"/> Mold Direct Exam |

| Sample # | Date Sampled** | Time Sampled** | Sample Identification (Employee, SSN, Bldg, Material, Type) | Wiped Area (ft²) | pH / Temp * | Time² | | Flow Rate³ | | Total⁴ Air |
|----------|----------------|----------------|---|------------------|--------------------------------------|-------|------|------------|------|------------|
| | | | | | | Start | Stop | Start | Stop | |
| L-21 | 10-21-16 | | 12x12 tan floor tile w/specs | | Main Floor / Seafood / Meat / Bakery | | | | | |
| L-22 | | | mastic to above | | | | | | | |
| L-23 | | | 12x12 white floor tile w/specs | | | | | | | |
| L-24 | | | mastic to above | | | | | | | |
| L-25 | | | 12x12 white floor tile w/specs | | | | | | | |
| L-26 | | | mastic to above | | | | | | | |
| L-27 | | | 12x12 green w/black spots floor tile | | Produce Area | | | | | |
| L-28 | | | mastic to above | | | | | | | |
| L-29 | | | 12x12 orange w/black spots floor tile | | | | | | | |
| L-30 | | | mastic to above | | | | | | | |

*Type: A=Area B=Blank P=Personal E=Excursion †Beginning/End of Sample Period ‡Pump Calibration in Liters/Minute ⁴Volume in Liters (time in min x flow in L/min)
 All soil and aqueous samples must be sent in adequate quantity for duplicate analysis to be performed per EPA requirements. Failure to perform a sample duplicate analysis, due to a lack of sample quantity, will lead to a disclaimer on the report. All problem jobs without customer response held over 30 days will be voided and disposed of.

| | | |
|---|---|---|
| Sampled by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Relinquished to lab by NAME <u>Nick Palmieri</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Sample Disposal <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee for excessive weight) Shipping Methods <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: _____ |
|---|---|---|

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.





SCHNEIDER LABORATORIES GLOBAL, INC.

WO Label

2512 West Cary Street, Richmond, Virginia 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
 www.slabinc.com e-mail: info@slabinc.com

| | | |
|---|--|---|
| Submitting Co. WESTERN ENV. SERVICES | Lab WO# | Phone 540-265-0888 |
| P O BOX 19021 | Acct # 1548 | Fax / Email 540-265-6798 |
| ROANOKE, VA 24019 | **State of Collection VA | **Cert. Required <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Project Name: Kroger R-215 | Special Instructions [include requests for special reporting or data packages] | |
| Project Location: 7480 Lee Hwy. Radford, VA | | |
| Project Number: #45.1 | | |
| PO Number: | | |

| Turn Around Time (TAT) | Matrix / Sample Type (Select ONE) | Tests / Analytes (Select ALL that Apply) | | |
|--|--|---|---|--|
| <input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day † <input checked="" type="checkbox"/> 1 business day* † <input type="checkbox"/> 2 business days* † <input type="checkbox"/> 3 business days* † <input type="checkbox"/> 5 business days* † <small>* Not available for all tests</small> <small>A job received past 3PM † will begin its TAT the next business day</small> <small>Schedule rush organics, multi-metals & weekend tests in advance.</small> | <small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input checked="" type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> <input type="checkbox"/> Soil <input type="checkbox"/> | Asbestos in Air <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) Miscellaneous Tests <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) Other <input type="checkbox"/> | Asbestos in Bulk <input checked="" type="checkbox"/> PLM <input type="checkbox"/> PLM (Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP <input type="checkbox"/> CAELAP (Point Count) <input type="checkbox"/> TEM (Chatfield) <input type="checkbox"/> | Metals-Total <input type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals TCLP <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) 10 day Microbiology <input type="checkbox"/> BACT (MPN & P/A) <input type="checkbox"/> Mold Direct Exam <input type="checkbox"/> |

| Sample # | Date Sampled** | Time Sampled** | Sample Identification (Employee, SSN, Bldg, Material, Type ¹) | Wiped Area (ft ²) | pH / Temp * | Time ² | | Flow Rate ³ | | Total ⁴ Air |
|----------|----------------|----------------|---|--------------------------------------|-------------|-------------------|------|------------------------|------|------------------------|
| | | | | | | Start | Stop | Start | Stop | |
| L-31 | 10-21-16 | | 12x12 white w/ black spots floor tile | Produce Area | | | | | | |
| L-32 | | | note to above | | | | | | | |
| L-33 | | | core base mastic | Main Floor / Meat / Seafood / Bakery | | | | | | |
| L-34 | | | | | | | | | | |
| L-35 | | | | | | | | | | |
| L-36 | | | carpet mastic @ Entrance | | | | | | | |
| L-37 | | | carpet mastic Upstairs Office | | | | | | | |
| L-38 | | | Rubber Stair Tread Mastic | Office Area | | | | | | |

¹Type: A=Area B=Blank P=Personal E=Excursion ²Beginning/End of Sample Period ³Pump Calibration in Liters/Minute ⁴Volume in Liters (time in min * flow in L/min)
 All soil and aqueous samples must be sent in adequate quantity for duplicate analysis to be performed per EPA requirements. Failure to perform a sample duplicate analysis, due to a lack of sample quantity, will lead to a disclaimer on the report. All problem jobs without customer response held over 30 days will be voided and disposed of.

| | | |
|--|--|---|
| Sampled by NAME <u>New Palmer</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Relinquished to lab by NAME <u>New Palmer</u> SIGNATURE <u>[Signature]</u> DATE / TIME <u>10-21-16</u> | Sample Disposal <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee for excessive weight) Shipping Methods <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: |
| <input type="checkbox"/> Sample return requested <input type="checkbox"/> Ambient temp <input type="checkbox"/> Ice <input type="checkbox"/> Cl <input type="checkbox"/> R <input type="checkbox"/> S <input type="checkbox"/> X <input type="checkbox"/> Receive a physical copy of report. | | |

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.

COMMONWEALTH of VIRGINIA

Department of Professional and Occupational Regulation

9960 Mayland Drive, Suite 400, Richmond, VA 23233

Telephone: (804) 367-8500

EXPIRES ON
07-31-2017

NUMBER
3303001204

BOARD FOR ASBESTOS, LEAD, AND HOME INSPECTORS
ASBESTOS INSPECTOR LICENSE



NICK PALMIERI
797 HIGHLAND DRIVE
ROANOKE, VA 24019-0000



Jay W. DeBoer
Jay W. DeBoer, Director

Status can be verified at <http://www.dpor.virginia.gov>

(SEE REVERSE SIDE FOR PRIVILEGES AND INSTRUCTIONS)

DPOR-LIC (05/2015)

(DETACH HERE)



COMMONWEALTH of VIRGINIA
Department of Professional and Occupational Regulation

BOARD FOR ASBESTOS, LEAD, AND HOME INSPECTORS
ASBESTOS INSPECTOR LICENSE
NUMBER: 3303001204 EXPIRES: 07-31-2017

NICK PALMIERI
797 HIGHLAND DRIVE
ROANOKE, VA 24019-0000



(FOLD)

Status can be verified at <http://www.dpor.virginia.gov>

DPOR-PC (05/2015)

