



January 11, 2017

TO: Tom Poole

RE: R-215 Within-the-Walls Remodel, Radford, VA
Asbestos Containing Material Survey (10/27/2016)

Asbestos Containing Material Survey Review

Jacob Ogonek Comments:

An Asbestos Containing Material (ACM) Survey was conducted for a Within-the-Walls remodel in an existing Kroger Co. building. Thirty-eight (38) samples were collected for inspection from throughout the property. Asbestos was not identified in any of the materials sampled.

As a result of the investigations, no confirmed ACM were detected. Therefore, no further action is required at this time. However, contractors should notify the GC of any suspect materials encountered that will be disturbed for further testing.

cc: C. Holcomb
B. Trauger